



Specifications for Fiberglass Bridge Hangers with 304 Stainless Steel Hardware

1. This specification details the requirements for hangers (suspension supports) used to support fiberglass conduit from bridge structures.
2. The hangers shall be shipped fully assembled with all necessary components. All nuts shall be tightened to “snug fit.”
3. The fiberglass components shall be manufactured using isophthalic polyester resin and contain UV inhibitors. They shall contain a fire retardant and exhibit low smoke generation. The fiberglass components shall be gray in color and shall meet or exceed the following. (see chart on following page)

Fiberglass Square Tube, Fiberglass Flat Bar and Fiberglass Round Spacer Tube

		English		Metric	
		Value	Units	Value	Units
Mechanical Properties	ASTM				
Tensile Strength	D638	30,000	psi	206.8	MPa
Tensile Modulus	D638	2.5 x10 ⁶	psi	17.2	GPa
Compressive Strength	D695	30,000	psi	206.8	MPa
Compressive Modulus	D695	2.5 x10 ⁶	psi	17.2	GPa
Flexural Strength	D790	30,000	psi	206.8	MPa
Flexural Modulus	D790	1.8 x10 ⁶	psi	12.4	GPa
Modulus of Elasticity		2.8 x10 ⁶	psi	19.3	GPa
Shear Modulus		0.45 x10 ⁶	psi	3.1	GPa
Short Beam Shear	D2344	4,500	psi	31.0	MPa
Punch Shear	D256	10,000	psi	68.9	MPa
Impact Strength	D256	25	ft-lbs/in	1.33	J/mm
Physical Properties	ASTM	Value	Units	Value	Units
Barcol Hardness	D2583	45			
24-Hour Water Absorption	D570	0.45%	max		
Density	D792	.062-.070	lbs/in ³	1.72-1.94	g/cc
Coefficient of Thermal Expansion	D696	4.4	10 ⁻⁶ in/in/°F	8	10 ⁻⁶ cm/cm/°C
Electrical Properties	ASTM	Value	Units	Value	Units
Arc Resistance	D495	120	seconds		
Dielectric Strength	D149	35	kv/in	1.37	kv/mm
Flammability Properties	ASTM	Value	Units	Value	Units
Tunnel Test	E84	25	max		
Flammability	D635	Nonburning			
UL	94	VO			
Smoke Chamber	E662	600-700			

Hangers shall be designed and fabricated in such a manner as to eliminate the possibility of crushing the square tube by tightening the nuts on the suspension or intermediate rods (the spacer tube shall rest on the bottom part of the square tube).

4. The support rods, intermediate rods, and all metallic hardware shall be stainless steel and shall meet or exceed the following:
 - Threaded Rod SS304 ASTM A193 grade B8
 - Hex nut ASTM SS304 A194 grade 8
 - Flat washer SS18-8
 - Lock washer SS18-8

Metal components that are custom fabricated shall be stainless steel 304 in accordance with ASTM specification A193/A193M-94b dated 1994.

5. The components of the hangers may include:
 - 2" x 1/2" (50.8mm x 12.7mm) Fiberglass flat bar, all holes on centerline, holes for support rods, 1" (25mm) from each end of plate. Length as required.
 - 2" x 2" x 1/4" (50.8mm x 50.8mm x 6.4mm) Fiberglass square tubing, all holes on centerline, holes for support rods, 1" (25mm) from each end of plate. Length as required.
 - 1" OD x 0.755" ID (25.4mm OD x 19.2mm ID) Fiberglass spacer tube. Length as required.
 - 3/4" (19mm) All thread rod with 2 nuts, 2 lock washers and 2 flat washers. All material shall be 316 stainless steel. Length as required.